2023. 09. 6-7. XII. Lakiteleki Tűzvédelmi Szakmai Napok

2023. 09. 6-7. XII. Lakiteleki Tűzvédelmi Szakmai Napok



Low pressure water mist system efficiency based on fire experiences.

Presenter: Gniewosz Siemiątkowski

Business Development Manager Central and East Europe





VID Fire-Kill - a leading low pressure Watermist manufacturer



- Is an ISO9001 accredited R&D, Production and Sales company focusing on innovative fire protection solution.
- Is the market leader withing the Low Pressure Watermist technology.
- Headquarter is located in Svendborg, Denmark where all R&D, testing and manufacturing is taking place.
- ~ 50 dedicated employees located in several countries.
- 4-500,000 components (nozzles, valves, pre-fab pipes, filters etc.) are manufactured and sold each year Globally.
- Was founded in 2002 by Mr. Carsten Palle using all is expert knowledge within sprinkler R&D. Since 2012 his son Mr. Alex Palle has been running the company, and the company is still 100% family owned.



Definition















Potential risks:

Public space with 2 big workshops areas


























Number of activated nozzles: 1

Result: fully extinguished before

fire service came on site

Water flow: 47l/min

Time to use class room again: **1h**

Refurbishemnt required: painting

the ceiling due to smoke stains











Full LPWM → Coverage

Fibre Storage Full LPWM Coverage

Process Building
Full LPWM
Coverage —

Full HPWM Coverage








Dimensions – Length = 37 m. Width = 10 m. Height = 9 m

The Storage Shed risks:


- Machinery.
- Vehicles.
- Loosely piled fibrous product.
- Building height.
- Varying fibre fuel heights.
- Open ended.




















- 6 Zones
- 3 Operating
- 203 lpm per zone
- 4 bar minimum on nozzles
- 2 x full duty pumps+ jockey





Fire accident no.1

- A Fire started in the Auger below the ceiling walkway when some bearings overheated and ignited the product on the auger and dropped into the pile.
- The Fire was partially shielded by the walkway.
- The Fire was sensed early by the flame detection.
- The system opens and the fire was extinguished at an early stage.
- The Fire Brigade attended from the monitoring system alert, but no intervention was required as the fire was extinguished.





Fire accident no.2


- Started when a vehicle came into the area and it is suspected the heat, or spark from the vehicle exhaust ignited material underneath the vehicle.
- The Fire was partially shielded by the vehicle.
- The Fire was sensed early by the flame detection.
- The system opens and the fire was extinguished at an early stage.
- The Fire Brigade attended from the monitoring system alert, but no intervention was required as the fire was extinguished.







Low Pressure Watermist





2023. 09. 6-7. XII. Lakiteleki Tűzvédelmi Szakmai Napok



KÖSZÖNÖM, HOGY MEGHALLGATTAK!